

Report Ref: KEBS/TES/E/244/11

PRIVATE SAMPLE

Date: 03 June 2011

- | | | | |
|---------------------------|----------------------------------------|-------------------------------|----------------------|
| 1. Description of Sample: | Airco Saver | 6. KEBS Sample Ref.No: | BS/07446/11 |
| 2. Sample Submitted by: | East Africa Wind Energy Limited | 7. Date of Receipt : | 12 April 2011 |
| 3. Customer Contact: | Leslie Sifa | 8. Date Analysis Started: | 14 April 2011 |
| 4. Customer's Ref. No: | Private | 9. Sample Submission Form No: | |
| 5. Customer's Address: | P.O. Box 84127-80100, MOMBASA | | |

10. Additional information provided by the customer:

EAWEI

11. Acceptance criteria-title and number of specification against which it is tested:


British Standard for Household and Similar Electrical Appliances-safety BS EN 60335-1

12. Parameters tested and Method(s) of test: as listed in the report below

LABORATORY TEST REPORT			
No.	Parameters	Results	Requirements
1.	Input and Current %	21% saving (36,000Btu/h; 4,200; 19A A/C)	As per manufacturer's claim, clause 10 the appliance shall cause to save 20% - 35% power consumption

COMMENTS/REMARKS:

The sample performed as shown



MICHAEL OGANGA - Manager Testing Electrical Laboratory
FOR: MANAGING DIRECTOR

03 June 2011
Date of Issue